

Display energy certificate (DEC)



ST MICHAELS CHURCH OF ENGLAND
PRIMARY SCHOOL
CONSTANTINE DRIVE
STANGROUND SOUTH
PETERBOROUGH
PE2 8SZ

Operational rating

D

Certificate number: 9999-1298-1110-9184-4034

Valid until: 31 October 2021

Total useful floor area: 2507.4143 square metres

Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO₂) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.

Score	Operational rating	This building	Typical
0-25	A		
26-50	B		
51-75	C		
76-100	D	85 D	
			----- 100 -----
101-125	E		
126-150	F		
150+	G		

This building's energy use

Energy use	Electricity	Other fuels
Annual energy use (kWh/m ² /year)	44.49	97.88
Typical energy use (kWh/m ² /year)	40	151.34
Energy from renewables	0%	0%

Previous operational ratings

Date	Operational rating
November 2020	85 D
November 2019	99 D
November 2018	90 D

Total carbon dioxide (CO₂) emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO₂.

Date	Electricity	Heating	Renewables
November 2020	61	48	0
November 2019	68	59	0
November 2018	80	39	0

Assessment details

Assessor's name

Accreditation scheme: Elmhurst Energy Systems Ltd

Employer/Trading name

Employer/Trading address

Issue date: 19 November 2020

Nominated date 1 November 2020

Assessor's declaration Not related to the occupier.